



Accreditation Institute for Assessment Body (Europe)

© For detail scope of our accreditation,  
visit NABL website : www.nabl-india.org

**TEST REPORT**

<b>TC655219000014181F</b>		<b>SMTL/WTR/ S-4053 / Date: 22/02/2021</b>	
<b>Name of work</b>	Testing of Water for Drinking Drinking		
<b>Details of sample</b>	Drinking Water		
<b>Report Submitted to.</b>	Hanumant Highschool, Mahuva		
<b>Reference No.</b>	Date:- 18/02/2021		
<b>Sample received Date</b>	18/02/2021		
<b>Condition of sample during receipt</b>	Sealed		
<b>Identification Mark</b>	WTR		
<b>Location of Sample</b>	Local		
<b>Name of Agency</b>	Hanumant Highschool, Mahuva		
<b>Lab No.</b>	WTR/219		
<b>Job No.</b>	S-4053		
<b>Starting Date of Test</b>	18/02/2021	<b>Completion Date of Test</b>	22/02/2021

Sr.No.	PARAMETERS	IONIC COMPOSITION IN P.P.M (mg/l)	Maximum Limit Permissible as per IS : 10500 : 2012
1	Colour Hazeen Unit.	Acceptable	10
2	Test.	Acceptable	--
3	Turbidity. N.T.U	NIL	10
4	pH of Water	6.80	6.5 TO 8.5
5	Carbonate. (Co <sub>3</sub> )	NIL	--
6	Bicarbonate (Hco <sub>3</sub> )	54.54	--
7	Calcium as Ca <sup>++</sup>	0.8	75
8	Magnesium as Mg <sup>++</sup>	4.30	30
9	Chloride as Cl -	30.07	250
10	Sulphate as So <sub>4</sub> -	9.71	150
11	Insoluble.	--	--
12	Sp. Gr.	--	--
13	T.D.S	56.0	500
14	Total Hardness As CaCo <sub>3</sub>	5.1	300
15	Conductivity MMoh/cm 25°C	0.220	0.05-1.0

**Remarks: Water is Suitable for drinkable purpose.**

Note :1)Test results relate to samples collected by Customer.2) Results/ reports are issued with specific understanding that SMTL with not in any case be involved in action following the interpretation of test results.3) The reports/results are not supposed to be used for publicity. 4)Test report shall not be reproduced except in full without written approval of Quality Manager/ Technical Manager.



For SMTL

  
**Authorised Signatory**

Sachindrasinh Yadav

Quality Manager

  
 22/3/21

**PRINCIPAL**  
**HANUMANT HIGH SCHOOL**  
**MAHUVA**
  
**MANAGER**  
**HANUMANT HIGH SCHOOL**  
**MAHUVA**

PROFRMA REGARDING SAFE DRINKING WATER AND SNITARY CONDITION CERTIFICATE.

No.c.o./washi/581

Date : 21-01-2021

It is certifiend that an inspection team headed by Er.M.K.SENTA & SENITORY INSPECTOR- SHANTILAL B. CHAUHAN (Name of officers with desingnation) from Mahuva Nagar Palika (name of Departmet/office) inspectd The HANUMANT HIGH SCHOOL (name & address of the school) on 21-01-2021 and found that the HANUMANT HIGH SCHOOL (name of the school) has safe drinking water facilities for the students and member of staff of the institution and maintaining the hygienic sanitation conditionin the schoool● building & the campus as per the neoms prescribed by the central/state/ U.T.Govt.

The above valid for a period of ONE YEARS



Signature With Seal : \_\_\_\_\_

Name : Sanjaybhai H.Patel

Designation : Mahuva Municipality

  
Chief Officer  
Mahuva Municipality

TO  
HANUMANT HIGH SCHOLL  
MAHUVA-BHAVNAGAR BY PASS  
NEAR GANPATI TEMPLE,MAHUVA

(Name & Address of the Institution)

D/Sheniteshn/nyu.computer/1....

  
22/3/21

**PRINCIPAL  
HANUMANT HIGH SCHOOL  
MAHUVA**

  
248

**MANAGER  
HANUMANT HIGH SCHOOL  
MAHUVA**