



Accreditation Institute for Assessment Body (Europe)

© For detail scope of our accreditation,
visit NABL website : www.nabl-india.org

**TEST REPORT**

TC655219000014181F		SMTL/WTR/ S-4053 / Date: 22/02/2021	
Name of work	Testing of Water for Drinking Drinking		
Details of sample	Drinking Water		
Report Submitted to.	Hanumant Highschool, Mahuva		
Reference No.	Date:- 18/02/2021		
Sample received Date	18/02/2021		
Condition of sample during receipt	Sealed		
Identification Mark	WTR		
Location of Sample	Local		
Name of Agency	Hanumant Highschool, Mahuva		
Lab No.	WTR/219		
Job No.	S-4053		
Starting Date of Test	18/02/2021	Completion Date of Test	22/02/2021

Sr.No.	PARAMETERS	IONIC COMPOSITION IN P.P.M (mg/l)	Maximum Limit Permissible as per IS : 10500 : 2012
1	Colour Hazeen Unit.	Acceptable	10
2	Test.	Acceptable	--
3	Turbidity. N.T.U	NIL	10
4	pH of Water	6.80	6.5 TO 8.5
5	Carbonate. (Co ₃)	NIL	--
6	Bicarbonate (Hco ₃)	54.54	--
7	Calcium as Ca ⁺⁺	0.8	75
8	Magnesium as Mg ⁺⁺	4.30	30
9	Chloride as Cl -	30.07	250
10	Sulphate as So ₄ -	9.71	150
11	Insoluble.	--	--
12	Sp. Gr.	--	--
13	T.D.S	56.0	500
14	Total Hardness As CaCo ₃	5.1	300
15	Conductivity MMoh/cm 25°C	0.220	0.05-1.0

Remarks: Water is Suitable for drinkable purpose.

Note :1)Test results relate to samples collected by Customer.2) Results/ reports are issued with specific understanding that SMTL with not in any case be involved in action following the interpretation of test results.3) The reports/results are not supposed to be used for publicity. 4)Test report shall not be reproduced except in full without written approval of Quality Manager/ Technical Manager.



For SMTL

Authorised Signatory

Sachindrasinh Yadav

Quality Manager

22/3/21

 PRINCIPAL
 HANUMANT HIGH SCHOOL
 MAHUVA

 MANAGER
 HANUMANT HIGH SCHOOL
 MAHUVA

PROFRMA REGARDING SAFE DRINKING WATER AND SNITARY CONDITION CERTIFICATE.

No.c.o./washi/581

Date : 21-01-2021

It is certifiend that an inspection team headed by Er.M.K.SENTA & SENITORY INSPECTOR- SHANTILAL B. CHAUHAN (Name of officers with desingnation) from Mahuva Nagar Palika (name of Departmet/office) inspectd The HANUMANT HIGH SCHOOL (name & address of the school) on 21-01-2021 and found that the HANUMANT HIGH SCHOOL (name of the school) has safe drinking water facilities for the students and member of staff of the institution and maintaining the hygienic sanitation conditionin the schoool● building & the campus as per the neoms prescribed by the central/state/ U.T.Govt.

The above valid for a period of ONE YEARS



Signature With Seal : _____

Name : Sanjaybhai H.Patel

Designation : Mahuva Municipality


Chief Officer
Mahuva Municipality

TO
HANUMANT HIGH SCHOLL
MAHUVA-BHAVNAGAR BY PASS
NEAR GANPATI TEMPLE,MAHUVA

(Name & Address of the Institution)

D/Sheniteshn/nyu.computer/1....


22/3/21

**PRINCIPAL
HANUMANT HIGH SCHOOL
MAHUVA**


248

**MANAGER
HANUMANT HIGH SCHOOL
MAHUVA**